


Exchanger Leak Testing - Chemical Tracers

Tracerco has been at the forefront of the development of online leak detection for the last 40 years.

The method allows the detection of leaks as small as 0.5%. However, customer demands to measure smaller leaks affecting product quality, has prompted extensive research to develop alternative online methods. Through the development of specialist chemical tracers leaks as small as 0.0001% are readily identified.

Project Field Test

In the following case study, Exchangers A and B were condensing naphta from a crude distillation column on the shell side using raw crude as the cooling media on the tube side. Customer laboratory results showed that the naptha was out of specification with regards to color, indicating that there may be damage to the internals of the crude column or a leak in an exchanger. A TRU-SCAN® was performed on the crude column and results indicated that there was no damage to the column internals, nor operational issues such as flooding or severe entrainment.




To address the need to find very small leaks, Tracerco carried out an extensive research and development program looking at the application of specialist chemical tracers. The chemical tracer approach can provide plant personnel new alternatives for investigating plant operating performance with the goal of reduced diagnostic and shutdown time.

A review of the process showed that there was no sample point between exchangers on the naphtha side, so a common sample point downstream of the bank of exchangers had to be used. However, there was an injection point before each of the two exchangers on the crude side (Figure 1). The first chemical tracer, T105, was injected into the high-pressure crude inlet to the bottom exchanger (A) of the bank of exchangers. This tracer passed through the crude side of the bottom exchanger and then to the top exchanger (B). As the tracer was injected into the feed, the first sample cylinder was opened, allowed to fill, and then closed. Additional sample cylinders were opened, filled, and closed at intervals appropriate to the system.

After the last sample was collected from the first test, a different chemical tracer, T205, was injected into the crude inlet line between the exchangers. The second chemical tracer passed through the crude side of the top exchanger (B) only. The sample point was the same as for the first test.

Sample cylinders were analyzed for tracer presence.

Figure 1 - Exchanger A and B schematic illustrating the two injection points and common sample point used.



Project Analysis

Flowrates of the crude and naphtha through the exchangers indicated that the residence time should have been about 2 minutes each.

Analysis of the first chemical tracer (T105) appeared in sample A5 with the maximum concentration of tracer seen in sample A6 (Figure 2). The residence times matching these samples was 2.5 and 3 minutes. Since the residence times were not known exactly, these results indicated a leak either near the crude outlet of the bottom exchanger (A) or near the crude inlet of the top exchanger (B).




Figure 2 - Tracer analysis data revealed strong positive tracer responses indicating that exchanger B was leaking.

The second tracer (T205), injected into the crude feed to the top exchanger, was detected in samples B2 and B3, with the highest concentration of tracer found in sample B2. Since the analysis only found tracer in the first 2 samples, the leak appeared to happen near the crude inlet of the top exchanger (B).

The test data showed a strong positive tracer response indicating that the top exchanger (B) was indeed leaking. But was the bottom exchanger (A) also leaking? The residence time of the chemical tracer found in the naphtha samples showed that the tracer had likely already passed through the bottom exchanger (A) and was near the entrance to the top exchanger (B). Therefore the conclusion was made that only the top exchanger (B) was leaking.

Based on the process rates through these exchangers, the amount of tracer injected, and the amount of tracer in the samples, the leak size was calculated to be approximately 100 ppm (0.01%)

Customer Conclusion

These exchangers were floating head design, and experience of this exchanger type when trying to detect small leaks was found to be very difficult and time consuming. With the knowledge that the B exchanger was leaking, the plant was able to shutdown and replace the leaking bundle and restart the unit with minimal downtime. After restart, the lab analysis showed the naphtha quality problem had been eliminated.

This chemical tracer approach is only offered by Tracerco and can provide plant personnel new alternatives for investigating plant operating performance with the goal of reduced diagnostic and shutdown time along with reduced maintenance costs.

For further information:

If you would like to obtain additional information on Tracerco's Process Diagnostics® technology please contact a technical advisor in your area to schedule an onsite presentation or visit our website at www.tracerco.com.

North American Headquarters

4106 New West Drive
Pasadena, TX 77507, USA
Tel 281 291 7769
Fax 281 291 7709
Toll Free 800 288 8970

Field Office Locations:

Corpus Christi, TX 78408, USA
Tel 361 888 8233
Concord, CA 94520, USA
Tel 925 687 0900
Paramount, CA 90723, USA
Tel 562 633 8800
Newark, DE 19702, USA
Tel 302 454 1109

Merrillville, IN 46410, USA
Tel 219 945 0400
Baton Rouge, LA 70820, USA
Tel 225 761 0621
Salt Lake City, UT 84119, USA
Tel 801 478 0736
Edmonton AB, T6E 6A6, Canada
Tel 1 780 469 0055

Sarnia, N7S 5G5, Canada
Tel 1 519 332 6160
Calgary, AB, T2Y 2Z7, Canada
Tel 1 403 931 6705
**Rio de Janeiro, RJ, Brazil,
CEP 22775-044**
Tel +55 21 3385 6800